

CONDITIONS



**BAKERSFIELD FIRE DEPARTMENT**  
Prevention Services  
2101 H Street  
Bakersfield, CA 93301  
Phone: 661-326-3979 • Fax: 661-852-2171

**HIGH-PILED COMBUSTIBLE STORAGE.** To use any building or portion thereof as a high- piled storage area exceeding 500 square feet (46.45 m<sup>2</sup>) (see definition in Article 81). Plans shall be submitted with applications for such permits in accordance with Article 81.

A permit constitutes permission to maintain, store, use or handle materials, or to conduct processes which produce conditions hazardous to life or property, or to install equipment used in connection with such activities. Such permission shall not be construed as authority to violate, cancel or set aside any of the provisions of this code. Such permit shall not take the place of any license required by law.

High-piled combustible storage is storage of combustible materials in closely packed piles or combustible materials on pallets, in racks or on shelves where the top of storage is greater than 12 feet (3658 mm) in height. When required by the chief, high-piled combustible storage also includes certain high- hazard commodities, such as rubber tires, Group A plastics, flammable liquids, idle pallets and similar commodities, where the top of storage is greater than 6 feet (1829 mm) in height.

Buildings containing high-piled combustible storage shall be in accordance with Article 81. In addition to the requirements of Article 81, aerosols shall be in accordance with Article 88, flammable and combustible liquids shall be in accordance with Article 79, and hazardous materials shall be in accordance with Article 80.

Storage of combustible paper records shall be in accordance with Article 81 and CFC Standard 81-4.

